

Building

01	Central unit number
02	Number of degree days
04	Operating hours
05	Date
07	Degree days last set day
09	Operating hours last set day
10	Date of last set day
11	Deg days last but one set day
13	Optg hours last but one set day
14	Date of last but one set day
15	Date of set day 1
16	Date of set day 2

SW-Version 4.0 CE1B2841E December 14, 2004 H 4 319 2510 0 0

User

Apartment

Meter

01	Meter number
02	Meter reading
04	Operating hours
05	Date
07	Meter reading last set day
09	Operating hours last set day
10	Date of last set day
11	Meter read last but one set day
13	Optg. hours last but one set day
14	Date of last but one set day

SW-Version 4.0 CE1B2841E December 14, 2004 H 4 319 2510 0 0

User

Apartment

Meter

21	Meter reading end of January
22	Meter reading end of February
23	Meter reading end of March
24	Meter reading end of April
25	Meter reading end of May
26	Meter reading end of June
27	Meter reading end of July
28	Meter reading end of August
29	Meter reading end of September
30	Meter reading end of October
31	Meter reading end of November
32	Meter reading end of December
86	Unit factor
87	Metering medium
88	Meter calibration date
90	Pulse valency

NNNN - DDDD

SW-Version 4.0 CE1B2841E December 14, 2004 H 4 319 2510 0 0

Diagnosis building

35	Outside temperature		
36	Heating limit temp for deg. days		
37	Room temp for degree days		
39	Input 1	Status	Optg hours
40	Input 2	E.g. 0 -- 1205 1	
41	Operating hours of burner 1		
42	Operating hours of burner 2		
43	Storage capacity	Size	Available
	memory card	E.g. 0 120 -- 0085 kB	
45	Number of SYNERGYR devices		
46	Number of H-bus / LPB devices		
48	Function of PC interface	0 = no device 1 = modem 2 = PC with ACS30 3 = PC with ACS Alarm	
50	Fault of central unit		
52	Software version central unit		
54	Production number central unit		

SW-Version 4.0 CE1B2841E December 14, 2004 H 4 319 2510 0 0

4	Diagnosis user	Apartment	Meter	04	Operating hours	Valve
				50	Fault	
				52	Software version	
				54	Production number	
				69	Minimum flow rate	
				70	Nominal flow rate	
				71	Room temperature	
				72	Room temperature setpoint	
				73	Flow temperature	
				74	Return temperature	
				75	Flow rate	
				76	Maximum flow rate	
				77	Pressure differential [mbar]	
				78	Opening ratio [%]	
				79	Valve position	
				81	Heating group / flow zone	
				83	Room unit 1 = none 3 = QAW20 2 = QAW10 4 = wrong type	
				91	Type of pulse source 0 = none 2 = Reed 1 = Namur	

SW-Version 4.0 CE1B2841E December 14, 2004 H4 319 2510 0 d

5	Control	Heating group	55	Start	Occupancy time
			56	End	
			57	Maximum room temperature	
			58	Normal room temperature	
			59	Reduced room temperature	
			60	Minimum room temperature	
			61	Room temp non-occup. time	
			62	Type of load comp Type Strategy Strategy E.g. 1 0.75	Per group
			63	Effect of load compensation	
			64	Active load compensation Status Setpoint change E.g. 1 1.5 °C	
			65	Number of apartments	
			67	LPB address Segm Device Heat circ heat group contr E.g. 01-01 1	

SW-Version 4.0 CE1B2841E December 14, 2004 H4 319 2510 0 d

6	Startup building	01	Central unit number
		03	Clock time 0 = standalone 1 = slave wo remote adj. 2 = slave w remote adj. 3 = master
		05	Date
		06	Weekday / time of day
		15	Date of set day 1
		16	Date of set day 2
		17	Summertime
		18	Mode of clock 0 = quartz 1 = 50 Hz mains
		19	Beginning of summertime Day - month
		20	Beginning of wintertime Day - month
		36	Heating limit temp. for deg. days
		37	Room temp. for degree days
		39	Operating hours input 1
		40	Operating hours input 2
		44	Number of apartments

SW-Version 4.0 CE1B2841E December 14, 2004 H4 319 2510 0 d

7	Startup user	Apartment	Meter	01	Meter number	*Standard data record
				02	Meter reading	
				53	<input type="checkbox"/> <input type="checkbox"/> Write standard data record	
				58	Normal room temperature*	
				59	Reduced room temperature*	
				69	Minimum flow rate	
				70	Nominal flow rate	
				76	Maximum flow rate	
				80	Location of valve* 0 = return 1 = flow	
				81	Heating group / flow zone	
				84	Control of valve 0 = fully closed 1 = fully open 2 = automatically	
				85	Selection of function* 0 = Δt creep flow and summer function off 1 = summer function off 2 = Δt creep flow off 3 = standard	
				86	Unit factor*	
				87	Metering medium*	
				88	Meter calibration date*	

SW-Version 4.0 CE1B2841E December 14, 2004 H4 319 2510 0 d


QUICK-INFO

Calling up information

1. Press one of the buttons on the left.
2. Press or to select the required page number, e.g. page 2 = user.
3. Press to select the page, meter or line number.
4. Press or to readjust the value.

Non-available data appear on the display as — — .

Example:



Setting the values

1. Adjustable values can be changed by pressing the buttons on the right.
Non-adjustable values are shown highlighted on the cards.
2. Simultaneous pressing of and makes a reset to the default value.

Storing on the memory card

1. Press while the memory card is inserted.
During the storage process, the display shows "DATA".

SW-Version 4.0 CE1B2B41E December 14, 2004 H 4 319 2510 0 0

SIEMENS

OZW30

Startup building	6		
		48	Selection of PC interface 1 = modem 2 = PC with ACS30 3 = PC with ACS Alarm
		66	Bus power supply 0 = off 1 = on
		84	Control of all valves 0 = fully closed 1 = fully open 2 = automatically
	85	Function selection WRV 0 = no valve kick 1 = only OPEN kick 2 = only CLOSE kick 3 = OPEN + CLOSE kick	
	89	Type of plant	
	97	Valve kick cycle [h]	
	99	<input type="button" value="←"/> <input type="button" value="→"/> Setup protocol	

SW-Version 4.0 CE1B2B41E December 14, 2004 H 4 319 2510 0 0

Startup user	7		
		89	Type of plant*
		90	Pulse valency* NNNN - DDDD
	91	Type of pulse source* 0 = none 1 = Namur 2 = Reed	
	92	Adapter subaddress	
	95	<input type="button" value="←"/> <input type="button" value="→"/> Read standard data record	
	99	<input type="button" value="←"/> <input type="button" value="→"/> Setup protocol	

*Std data record

SW-Version 4.0 CE1B2B41E December 14, 2004 H 4 319 2510 0 0

Error codes

11	Parameter settings	51	Flow temperature sensor
12	Data overrun in RAM	52	Return temperature sensor
13	Data overrun in EEPROM	53	Room temperature sensor
15	Hardware error	54	Flow measurement
16	Valve actuating force	55	Pulse input (Namur)
17	Common fault room unit	56	Measured values outside limits
18	Error heat metering	61	Unit cover open
21	Power supply	62	Manual adjustment made
22	Battery memory card	63	Strong magnetic field
23	Battery central unit	71	Alarm input 1
31	Address collision building bus	72	Alarm input 2
33	Short-circuit building bus	73	Alarm input 3
34	Communication breakdown	74	Alarm input 4
35	Memory card	75	Alarm contact room unit
36	Formating memory card	76	Common alarm LPB
37	Write protection memory card	82	Valve stroke impeded
38	Memory card full	83	Risk of frost
41	Communication room unit	91	Configuration error
42	Communication heat meter	92	Number of apartments
44	Two clock time masters	95	Configuration H-bus or LPB
50	Measured value acquisition		

