



Declaration of conformity

Company

Siemens Building Technologies AG
HVAC Products
Gubelstrasse 22
CH-6301 Zug

hereby declares that all pressure sensors supplied by HVAC Products and carrying the legal brand name **SIEMENS** comply with all legal, normative and functional requirements.

For all these pressure sensors whose CE declaration of conformity does not refer to the pressure equipment directive 97/23/EEC, following applies in compliance with the pressure equipment directive 97/23/EEC:

Pressure sensors with a maximum permissible pressure up to 0.5 bar are not subject of the aforementioned directive.

According to clause 1, paragraph 2 of that directive, pressure sensors with a maximum permissible pressure of more than 0.5 bar are to be classified under piping. The pressure sensors have nominal sizes of DN < 25 and, therefore, need not comply with the requirements of that directive, clause 3, paragraph 1.3. According to clause 3, paragraph 1.4, they may not be used as safety components however.

As per clause 3, paragraph 3, we are committed to follow good engineering practice. In agreement with the pressure equipment directive, a CE declaration of conformity cannot be issued.

Siemens Building Technologies AG
HVAC Products: Sensors

A handwritten signature in black ink, appearing to read 'James Baiges'.

James Baiges
Head of Sensors

Siemens Building Technologies AG
Building Automation

A handwritten signature in black ink, appearing to read 'Konrad Meier'.

Konrad Meier
Head of Hardware Compliance