

**SIEMENS**

***MK8000 OPC Server Interface  
Specification for Sintony SI410***

Data and design subject to change  
without notice. / Supply subject to  
availability.

© Copyright by  
Siemens Switzerland Ltd

We reserve all rights in this document and  
in the subject thereof. By acceptance of the  
document the recipient acknowledges these  
rights and undertakes not to publish the  
document nor the subject thereof in full or  
in part, nor to make them available to any  
third party without our prior express written  
authorization, nor to use it for any purpose  
other than for which it was delivered to him.

## Sintony SI410

---

The panel comes with 16 zone inputs out of the box, expandable to 448. Zones can be assigned to up to 16 partitions, which can be assigned to 4 "clusters." This uniquely flexible structure allows up to 16 independent installations or systems with up to 128 arming groups to be run from a single Sintony 410 panel.

16 user event memories are provided (one for each partition), as well as an installer event memory. Event memories can be read locally from the keypad or a printer/PC or remotely via a telephone connection.

The Sintony 410 can integrate access control into the security system, using up to 32 card Wiegand card reader interfaces for up to 500 users.

Siemens' advanced E-Bus allows connection of multiple devices to a single four wire cable. Audio and video buses are also available for alarm verification and two way communication, with the addition of two more wires for each bus, allowing the complete multimedia system to run on a single eight core cable..

The Sintony 410's communicator can transmit all major alarm formats to up to two central stations, as well as sending plain text messages to up to two PCs. It can also send a message to a pager. The addition of the SMV11 voice module allows voice messages to be transmitted.

Programming of Sintony control panels can be carried out through the keypad, a laptop computer or by remote upload download. Programming can be downloaded by the installer onsite by connecting to an unattended remote computer, thanks to Siemen's unique "parameter server" feature.

## Sintony Application - ( INNOAPMN )

---

The `Sintony Application` object represents the entire Si410 and the geographical area covered by the intrusion protection.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

1000 Quiet ✓

No abnormal conditions present.

---

1351 Anomaly Ack ✓

The event has been acknowledged.

---

1369 Not Aligned

The control unit is not aligned to the field.

---

1370 Alignment In Progress

The alignment fase is in progress.

---

1999 Fault Ack ✓

A faulty condition has been detected on the communication link to the Sintony; the event has been acknowledged.

---

2051 Vitality Fault ✓

Missing vitality message (heartbeat): trouble in the communication link.

---

**Control Unit - ( INNOCCGE )**

---

The `Control unit` object represents the possible faulty conditions related to the Sintony control unit, and to the general health of the physical subsystem.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

**Remote transmission - ( INNORCGE )**

---

The Remote Transmission object covers the states of the remote transmission device.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

1000 Quiet ✓

No abnormal conditions present.

---

1300 Disarmed ✓

---

**Power Supplies - ( INNOPSET )**

---

The Power Supply object reports the conditions determined by power supply monitoring logic.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

## Remote Keypads - ( INNOKBET )

---

The 'Remote Keypads' object presents the possible conditions related to the remote Terminal.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

401 Alarm & Tamper Ack

This event is the combination of the Alarm and Tamper state. The event has been acknowledged.

---

501 Alarm Ack

The event has been acknowledged.

---

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

---

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---



**Radio Gateway - ( INNOCKET )**

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

Card readers - ( INNOCRET )

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

**Output transponder - ( INNOOBET )**

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

I/O transponder - ( INNOIBET )

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

**Audio Video Verifiers - ( INNOVEET )**

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

**E-Bus Gateway - ( INNOEPET )**

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

## System - ( INNOORGE )

The `System` object represents the possible general conditions related to the Sintony control unit.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

400 Alarm & Tamper Unack ✓ ✓

This event is the combination of the Alarm and Tamper state. The event should now be acknowledged by the operator.

401 Alarm & Tamper Ack ✓

This event is the combination of the Alarm and Tamper state. The event has been acknowledged.

501 Alarm Ack ✓

The event has been acknowledged.

511 Alarm & Fault Ack ✓

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

900 Tamper Unack ✓ ✓

The event should now be acknowledged by the operator.

910 Tamper & Fault Unack ✓ ✓

This event is the combination of the Tamper and Fault state. The event should now be acknowledged by the operator.

911 Tamper & Fault Ack ✓

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

1000 Quiet ✓

No abnormal conditions present.

1200 Armed ✓

The user is Logged In

1351 Anomaly Ack

✓

The pannel has a new configuration. The event has been acknowledged.

---

1999 Fault Ack

✓

The event has been acknowledged.

---



Cluster - ( INNOSEGE )

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

1000 Quiet

No abnormal conditions present.

---

1300 Disarmed

---

Partitions - ( INNOZOGÉ )

Multistate		Commands											
		1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status
500	Alarm Unack	✓			✓							✓	
The event should now be acknowledged by the operator.													
501	Alarm Ack				✓							✓	
The event has been acknowledged.													
502	Alarm Unreset				✓							✓	
The event should now be reset by the operator.													
950	Active				✓			✓				✓	
The event has been acknowledged.													
1000	Quiet				✓							✓	
No abnormal conditions present.													
1300	Disarmed			✓								✓	
The event has been acknowledged.													
1351	Anomaly Ack				✓							✓	
The event has been acknowledged.													

Rooms - ( INNOROGE )

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

1000 Quiet

No abnormal conditions present.

---

1300 Disarmed

---

**Outputs - ( INNOOUGE )**

This object represents the status of the output in the Sintony control unit.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

950 Active

✓

1000 Quiet

✓

✓

No abnormal conditions present.

1100 Test

✓

✓

**Horns - ( INNOHOGE )**

---

The `Horn` object represents a status of the horn device.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

950 Active

✓

---

1000 Quiet

✓

✓

No abnormal conditions present.

---

1100 Test

✓

✓

---

## Bypassable Inputs - ( INNOBIGE )

The 'Bypassable Input' object represents the conditions related to the Bypassable Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status
501 Alarm Ack										✓		
The event has been acknowledged.												
511 Alarm & Fault Ack										✓		
This event is the combination of the Alarm and Fault state. The event has been acknowledged.												
911 Tamper & Fault Ack					✓					✓		
This event is the combination of the Tamper and Fault state. The event has been acknowledged.												
950 Active							✓			✓		
1000 Quiet					✓					✓		
No abnormal conditions present.												
1100 Test							✓			✓		
1351 Anomaly Ack					✓					✓		
The event has been acknowledged.												
1999 Fault Ack					✓		✓					
The event has been acknowledged.												

Generic inputs - ( INNOINGE )

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

---

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

---

950 Active

---

1000 Quiet

✓

No abnormal conditions present.

---

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

---

1999 Fault Ack

✓

The event has been acknowledged.

---

## Serialcom Inputs - ( INNOBISC )

The 'Serialcom Inputs' object represents the conditions related to the Serialcom Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.



## Technical Inputs - ( INCOINGE )

The `Technical Inputs` object represents the conditions related to the Technical Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.

## Silent Panic Inputs - ( INPAINSL )

The 'Silent Panic Inputs' object represents the conditions related to the Silent Panic Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.

## Audible Panic Inputs - ( INPAINAB )

The `Audible Panic Inputs` object represents the conditions related to the Audible Panic Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.

## Tamper Inputs - ( INTAINGE )

The `Tamper Inputs` object represents the conditions related to the Tamper Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.

## Burglary Inputs - ( INBUINGE )

The `Burglary Inputs` object represents the conditions related to the Burglary Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.

## Bypassable Burglary Inputs - ( INBUBIGE )

The 'Bypassable Burglary Inputs' object represents the conditions related to the Bypassable Burglary Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status
501 Alarm Ack												✓
The event has been acknowledged.												
511 Alarm & Fault Ack												✓
This event is the combination of the Alarm and Fault state. The event has been acknowledged.												
950 Active												✓
1000 Quiet					✓							✓
No abnormal conditions present.												
1100 Test							✓					✓
1351 Anomaly Ack					✓							✓
The event has been acknowledged.												
1999 Fault Ack					✓		✓					
The event has been acknowledged.												

## Burglary 24h Inputs - ( INBUIN24 )

The `Burglary 24h Input` object represents the conditions related to the Burglary 24h Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

✓

The event has been acknowledged.

1999 Fault Ack

✓

✓

The event has been acknowledged.

## Burglary 24h Bypassable Inputs - ( INBUBI24 )

The 'Burglary 24h Bypassable Input' object represents the conditions related to the Burglary 24h Bypassable Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status
501 Alarm Ack										✓		
The event has been acknowledged.												
511 Alarm & Fault Ack										✓		
This event is the combination of the Alarm and Fault state. The event has been acknowledged.												
950 Active										✓		
1000 Quiet					✓					✓		
No abnormal conditions present.												
1100 Test							✓			✓		
1351 Anomaly Ack					✓					✓		
The event has been acknowledged.												
1999 Fault Ack					✓		✓					
The event has been acknowledged.												



## Fire Inputs - ( FIDEINGE )

The 'Fire Inputs' object represents the conditions related to the Fire Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.

## Emergency Exit Inputs - ( INBUINEE )

The 'Emergency Exit Inputs' object represents the conditions related to the Emergency Exit Inputs.

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

501 Alarm Ack

The event has been acknowledged.

511 Alarm & Fault Ack

This event is the combination of the Alarm and Fault state. The event has been acknowledged.

950 Active

1000 Quiet

✓

No abnormal conditions present.

1100 Test

✓

1351 Anomaly Ack

✓

The event has been acknowledged.

1999 Fault Ack

✓

The event has been acknowledged.

LSN Gateway - ( INNOCKGE )

---

Multistate	Commands											
	1-Ack	2-Reset	4-Arm	8-Disarm	16-Test	32-Active	64-Quiet	128-Disc	256-Conn	512-Block	1024-Man	2048-Status

901 Tamper Ack

The event has been acknowledged.

---

911 Tamper & Fault Ack

This event is the combination of the Tamper and Fault state. The event has been acknowledged.

---

1000 Quiet

No abnormal conditions present.

---

1999 Fault Ack

The event has been acknowledged.

---

Siemens Switzerland Ltd  
Building Technologies Group  
International Headquarters  
Fire Safety & Security Products  
Gubelstrasse 22  
CH-6301 Zug  
Tel +41 41 724 24 24  
Fax +41 41 724 35 22  
www.sbt.siemens.com

Document no.	008597_d_en		
Edition			