



Certificate of Compliance

Certificate: 2164659 (LR84214)

Master Contract: 155118

Project: 2164659

Date Issued: 2009/05/22

Issued to: Siemens Building Technologies, Inc.

1000 Deerfield Pky
Buffalo Grove, IL 60089-4513
USA
Attention: Mr. Adam Jablonski

The products listed below are eligible to bear the CSA Mark shown



A. Yeung P. Eng.

Issued by: Anthony Yeung P. Eng.

Authorized by: Rick Morrison, P. Eng.,
Product Group Manager

Rick Morrison

PRODUCTS

CLASS 3221 01 - VALVES

Electrically Operated 3-Way Oil Valve, Models VOG15.011U1 & VOG15.012U1 rated at 110/120 VAC, 50/60 Hz, 20 VA, 300 psi max., fluid temperature 0 to 148 °C with Proof of closure switch and Auxiliary switch contacts rated at 250 Vac, 6.0 amp, Class H (180. °C) insulation.

Note: The subject valves are for oil Type No. 02, 04, 05 and 06 with Proof of closure switch and auxiliary switch.



Certificate: 2164659 (LR84214)

Master Contract: 155118

Project: 2164659

Date Issued: 2009/05/22

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 0 - General Requirements - Canadian Electrical Code, Part II

CSA Standard C22.2 No. 139 - Electrically Operated Valves



Supplement to Certificate of Compliance

Certificate: 2164659

Master Contract: 155118

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2164659	2009/05/22	Electrically Operated Valve