


RWD68 Universal Controller
Application 57
W/S setpoint selection-analogue

Room temperature control
 Hot water control valve
 DX cooling

- Control (P or PI)
- Room temperature control
- Proportional control (0..10Vdc) of the hot water valve.
- On/off control of DX cooling (refrigeration package unit)
- Winter / summer mode selection of Y1 as determined by analogue input (X2)
- Winter / summer setpoint selection
- Optional day / night set point adjustment .



Supplemental features

Control

- Room temperature sensor can be selected as Ni1000, Pt1000, or active sensor.
- Adjustable dead zone with separate heating and cooling set points.
- Adjustable differential of digital output Q1.
- Adjustable proportional band of analogue output Y1.
- Integral action function selection and adjustment.
- Outside air temperature sensor can be selected as Ni1000, Pt1000, or active sensor.
- Winter / summer selection of heating and cooling mode of the Y1 output as selected by analogue input into auxiliary input X2 sensing outside air temperature.

Operating modes

- Day / night set points can be selected via time clock or switch.

Safety functions

- Safety functions are built into the condensing unit of the refrigerated split system.

Description of operation

The temperature sensor senses the room conditions and on a fall in temperature the RWD68 via Y1 analogue output modulates the hot water valve as determined by the heating set point and proportional band (XP) settings.

On a rise in temperature the RWD68 via the Q1 digital output switches the condensing unit of the refrigerated split system to provide cooling as determined by cooling set point and differential settings.


When the outside air temperature sensor senses the outside air temperature has exceeded summer set point, the controller set points for Y1 are adjusted to the summer set point, and the Y1 output reverses it's action from heating to cooling mode.

The water supplied to the Y1 control valve must be also change from heating water to chilled water from the central plant.


This application results in Y1 supplying heating during the winter, and supplementary cooling during summer.

Heating and cooling sequences

Function diagram



Connection diagram



RWD68

- N1 RWD68 controller
- X1 Main temperature sensor
- X2 Outside air temperature sensor.
- S1 Time clock or switch for day/night setpoint select
- Q1 Potential-free relay contacts for 2-position
- Y1 Heating control valve
- CU Condensing unit.
- PC Personal computer

Main Display

The main display shows ,

- Whether Q1 is On or Off (= off, = on)
- Y1 output in Volts dc. (0..10V = 0..100% range)
- Whether day or night set point is selected. (= day, = night)
- X1 value (room temperature) in ° C.

Other displays are available by pressing the + button, and the various displays are listed below in sequence from the main display.

On entering any of the four set point displays, the setpoint on display can be adjusted by pushing the enter/save button, increase value by pressing the + button or decrease the value by pressing the - button, and when the required value is reached, press the enter/save button to save the new value.

The alternative displays return to the main display after 20 seconds.

| Press buttons | Action | Current display | Selected display | Selected display comments. |
|--|---------------|--|--|---|
| <input checked="" type="triangle-up"/> | Push + button | Q1 Y1 <input checked="" type="checkbox"/> X1 | Y1 SP – h <input checked="" type="checkbox"/> 24.0c | Y1 heating day set point. (winter) |
| <input checked="" type="triangle-up"/> | Push + button | Y1 SP – h <input checked="" type="checkbox"/> 24.0c | Y1 SP – c <input checked="" type="checkbox"/> 21.0c | Y1 cooling day set point. (summer) |
| <input checked="" type="triangle-up"/> | Push + button | Y1 SP – c <input checked="" type="checkbox"/> 21.0c | Q1 SP – c <input checked="" type="checkbox"/> 16.0c | Q1 heating day set point. |
| <input checked="" type="triangle-up"/> | Push + button | Q1 SP – c <input checked="" type="checkbox"/> 16.0c | Y1 SP – h <input checked="" type="checkbox"/> 16.0c | Y1 heating night set point. (winter) |
| <input checked="" type="triangle-up"/> | Push + button | Y1 SP – h <input checked="" type="checkbox"/> 16.0c | Y1 SP – c <input checked="" type="checkbox"/> 13.0c | Y1 cooling night set point. (summer) |
| <input checked="" type="triangle-up"/> | Push + button | Y1 SP – c <input checked="" type="checkbox"/> 13.0c | Q1 SP – c <input checked="" type="checkbox"/> 32.0c | Q1 cooling night set point. |
| <input checked="" type="triangle-up"/> | Push + button | Q1 SP – c <input checked="" type="checkbox"/> 32.0c | X1 18.0c | X1 - main temperature sensor reading |
| <input checked="" type="triangle-up"/> | Push + button | X1 18.0c | X2 24.0c | X1 – outside air temperature sensor reading |
| <input checked="" type="triangle-up"/> | Push + button | X2 24.0c | Y1 5.0 | Y1 – heating analogue output value in Vdc to one decimal point |
| <input checked="" type="triangle-up"/> | Push + button | Y1 5.0 | Q1 OFF | Q1 – cooling digital output, display shows if relay is on or off. |
| <input checked="" type="triangle-up"/> | Push + button | Q1 OFF | WIN/SUM <input checked="" type="checkbox"/> 57 ANLG | Control sequence diagram and application number display. |
| <input checked="" type="triangle-up"/> | Push + button | WIN/SUM <input checked="" type="checkbox"/> 57 ANLG | Q1 Y1 <input checked="" type="checkbox"/> X1 | Back to main display. |

Values shown are either default values or nominated for information only

Alternatives

- 1) Modulating hot water valve and two position chilled water valve.