

EC type examination certificate

CE-0085CL0280

product identification no.

field of application	EC Gas Appliances Directive (2009/142/EC)
owner of certificate	Siemens Switzerland Ltd. Building Technologies Group Gubelstrasse 22, CH-6301 Zug
distributor	Siemens Switzerland Ltd. Building Technologies Group Gubelstrasse 22, CH-6301 Zug
product category	accessories for gas appliances/pressure equipment: Manostat for gas, air and flue gas (4107)
product description	Differential manostat for air and non-aggressive gases
model	QBM-...
countries of destination	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK
test reports	type testing: 10/111/4107/640 from 24.08.2010 (EBI)
basis of type examination	EU/2009/142/EG (30.11.2009) DIN EN 1854 (01.07.2006)

file number 10-0584-GEE
17.09.2010 Rie A-1/2
date, issued by, sheet, head of certification body

DVGW CERT GmbH - notified by the government of the Federal Republic of Germany and officially registered by the European Commission for conformity assessment of gas appliances

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 BonnTelefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

ZLS-ZE-527/07

type	technical data	remarks
QBM81-...	ambient temperature range: -30...+85 °C maximum operating pressure: 50 mbar	

type variation	explanations
QBM81-3, QBM9900-3; QBM9901-3	set range: 0,2...3 mbar
QBM81-5	set range: 0,5...5 mbar
QBM81-10	set range: 1...10 mbar
QBM81-20	set range: 5...20 mbar
QBM81-50	set range: 10...50 mbar

hints of utilization / remarks

Pressure connection: hosesport Ø 6 mm

Protection code: II

installation position: any, for switching-on points < 0,3 mbar vertical or horizontal with electric connections downward