



### Supplier's declaration of conformity

Section 182 of the Australian Radiocommunications Act 1992

#### Instruction for completion

This completed form remains with the supplier as part of the documentation required for the compliance records

#### Supplier's detail

**Siemens Switzerland Ltd**  
**Building Technologies Division**  
International Headquarters  
Gubelstrasse 22  
CH - 6301 Zug

**SIEMENS LTD**  
**Building Technologies Division**  
885 Mountain Highway  
Bayswater VIC 3153  
AUSTRALIA

Supplier Identification Mark (Trademark): **SIEMENS**  
Australian company number (ACN): **004 347 880**

#### Product details

Product line: **Symaro™ Pressure Sensors**  
• **QBE9002-PxxU**

Reference the attached list of product- and stock number

#### Compliance with Radiocommunications (Electromagnetic Compatibility) Standard 2008

The above mentioned product complies with the requirements of the Radiocommunications (Electromagnetic Compatibility) Standard 2008. Evidence of compliance is demonstrated by test reports to the following applicable standards

#### Applicable standards

**AS/NZS 61000-6-3:2007 / EN 61000-6-3: 2007**  
Generic standards – Emission standard for residential, commercial and light-industrial environments

#### Declaration

I hereby declare that the product mentioned above complies with the requirements of the Radiocommunications (Electromagnetic Compatibility) Standard 2008. All products supplied under this declaration will be identical to the product identified above.

#### Control Products & Systems (CPS)

sig. **i. V. Franz Josef Kammerl**  
Head of System & Room Automation  
IC BT CPS SRA

#### Control Products & Systems (CPS)

sig. **i. V. André Muff**  
Head of Competence Center Zug  
IC BT CPS R&D ZG

Product number	Stock number	additional information
[ASN]	[SSN]	
QBE9002-P10U	S55720-S274	-1....9 bar / 0...10 V
QBE9002-P25U	S55720-S275	-1...24 bar / 0...10 V
QBE9002-P60U	S55720-S276	-1...59 bar / 0...10 V