

## AMEV attestation for certified BACnet devices

1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	Siemens Schweiz AG	
Product name	DESIGO PX	
Product model number	PXC001-E.D KNX	
Standard device profile	B-BC	BACnet protocol vers. / rev. 1.12
Firmware revision	FW=V6.00.024 KNX S-mode / SBS=11.01 / FLI=06.00 / BBI=13.06	

Data link layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input type="checkbox"/> MS/TP baud rates:	
	<input type="checkbox"/>	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Networking options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by Foreign Devices
	<input type="checkbox"/> Router, medium:	
Character set	<input checked="" type="checkbox"/> UTF-8	
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

2. The device supports BACnet functions as per AMEV profile:

<input type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of: .....
<input checked="" type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of: V 1.2 29.01.2014
<input type="checkbox"/> AMEV profile .....	As of: .....

3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab MBS dated 26.08.2015 number VG 2015_10936_2
<input checked="" type="checkbox"/> AMEV recommendation BACnet V 1.2 As of: 29.01.2014 (see <a href="http://www.amev-online.de">www.amev-online.de</a> )

4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BTL-30053 (see <a href="http://www.bacnetinternational.net/btl">http://www.bacnetinternational.net/btl</a> )
---

Stuttgart, 25.04.2017



Dr.-Ing. Bernhard Hall  
Vermögen und Bau Baden-Württemberg  
Rotebühlplatz 30  
70195 Stuttgart  
Telefon +49 711 6673-3433  
Email Bernhard.Hall@vbv.bwl.de

(AMEV chairman BACnet)



WSP Cert

Dr.-Ing. Frank Bitter  
Kapuzinerweg 7  
D-70374 Stuttgart  
Telefon +49 711 953922-0  
Telefax +49 711 953922-66

(BACnet certification body)