# **SIEMENS**

## Indoor/Outdoor Service Entrance Module

Catalog Number	
☐ WB31200C	
☐ WB31200CU	

Type 3R

#### Module Rating:

1200 Amps, Max; See main breaker for actual rating. 208Y/120 Volts~, 3 Phase, 4 Wire 240/120 Volts~, 3 Phase, 4 Wire, Delta (B Phase is High Leg) 240 Volts~, 3 Phase, 3 Wire

For installation by Qualified Person in accordance with all local electrical codes and/or the National Electrical Code ®.

**Suitable Only For Use As Service Equipment** unless bond strap is removed and ground lug is relocated to back of enclosure. See schematic. Apply appropriate label provided next to breaker handle.

For overhead or underground service. When LLP1200 is installed, installation is underground only.

## Use 75°C Copper or Aluminum Conductors.

Terminals A. B. C and N:

Wire size (4) 1/0-500 kcmil CU/AL. Torque terminals to 375 lb.in.

Ground terminal G: Wire size #4-250 kcmil. Torque terminal to 250 lb.-in.

Circuit breaker trip position is indicated by handle position midway between ON and OFF. To reset, move handle to OFF position, then turn ON.

### **Short Circuit Current Rating**

This device has a maximum short circuit current rating of 100,000 amps RMS symmetrical at 240 Volts ~. The actual short circuit current rating is limited to the interrupting capacity of the circuit breaker installed. Replacement breakers must be manufactured by Siemens and must be of the correct type and rating as indicated in the table below. Use of other circuit breakers in this device will void the warranty.

Breaker Type	Rating
NXD6	65k AIC
HNXD6	100k AIC

USE ONLY NON-INTERCHANGEABLE TRIP BREAKER TYPES

D

See adjacent labels for additional marking information.

49311155

Siemens Industry, Inc. Norcross, Georgia U.S.A.

40900011 0101 Rev.C

# **SIEMENS**

### **Siemens Accessories**

 Hub Cover Plate
 EC56933S

 GND Bar Kit
 ECLX069M

Breaker Lug Kit (factory installed) . . LK34500 (kit includes 4 lugs)

Alternate Breaker Lug Kit . . . . . . . LK33750 - (3) 500-750 kcmil, Torque 375 lb.-in. (kit includes 4 lugs)

Lug Landing Pad\*.....LLP1200 (lugs ordered separately)
UNDERGROUND USE ONLY

\*Kit contains mounting instructions and NEMA stud pattern for use with mechanical and compression lugs. See table below for recommended lugs.

 Connect Modules Using:
 Cat. No.
 Torque

 Single Bolt Joint
 SBJ4
 400-480 lb-in (35-40 ft.-lb.)

 Quick Connect
 QC4
 400-440 lb-in (35-36 ft.-lb.)

Lugs for Phase and Neutral Connections (not supplied)					
NEMA Lug <sup>①</sup>	MFG	Wire Range	Туре	No. Wires per phase	Torque (lbin.)
LK33750N2 Siemens 300-	300-750 kcmil	00-750 kcmil Mechanical	1	500 ②	
LK33/30INZ	33/50INZ Siemens	300-750 KCIIIII	Wiednanicai	2	500 ②
LK34500N2	Siemens	1/0-500 kcmil	Mechanical	4	500
2ACL-500	ILSCO	500 kcmil	Compression	4	NA ③
2ACL-750	ILSCO	750 kcmil	Compression	3	NA ③

- Order one mechanical lug kit for main breaker and neutral conversions. Contact lug manufacturer for compression lug quantities supplied for each kit.
- ② Kit contains more than one lug type. Reference kit instruction sheet for the actual torque value for each lug type.
- 3 See lug manufacturer's instruction sheet supplied with the connector for tool, die, and number of crimps.

#### IMPORTANT - for use with:

Module	Siemens Series#	Murray Series#
Main Breakers	. (W)MC, WB, WEB	. DB W
Switches	. WMP, WMS, WS, WES	. DPT W, DT W
Tap/Terminal Boxes	. WMTB, WTB, WET	. DTB W
Pull Boxes	. WMMB, WPB, WAPB	. DPB W
Meter Module	. WMM, WxMM, WMT, WML, WMK	. DG W, DC W, DL W
Extension Box	. WMEX, WSP	.DS
Bussed Elbow	. (W)BE	. DL

Use HD Type Hubs if required		
Trade Size (in)	Catalog No.	
3"		
3-1/2"	EC56857	
4"	EC56858	


Equipment Ground Bars		
Small Terminals	Large Terminals	
Wire Range / Torque 10-14 AWG 20 lb-in	Wire Range / Torque	
10-14 AWG 20 lb-in	10-14 AWG 35 lb-in	
8 AWG 25 lb-in	8 AWG 40 lb-in	
6 AWG 35 lb-in	1/0-6 AWG 45 lb-in	


Important: Do not allow petroleum based (hydrocarbon) sprays, chemicals, solvents or any paint to contact interior components. Petroleum based chemicals can cause degradation of electrical insulating materials.

49311156

Siemens Industry, Inc. Norcross, Georgia U.S.A. D 40900011 0201 Rev.C

© 2009 Copyright Siemens Industry, Inc.





<sup>®</sup> The National Electrical Code is a registered trademark of the National Fire Protection Association.
© 2009 Copyright Siemens Industry, Inc.