SIEMENS

Indoor/Outdoor Service Entrance Module

Catalog Number

Enclosure

WES1800BU

Type 3R

Module Rating:

800 Amps, Max; See fuse for actual rating,

120/240 Volts~, 60 HZ, 1 Phase, 3 Wire

208Y/120 Volts~, 60 HZ, 1 Phase, 3 Wire (from 3 Phase, 4 Wire network)


For installation by Qualified Person in accordance with all local electrical codes and/or the National Electrical Code ®

Meets EUSERC specifications.

Suitable Only For Use As Service Equipment unless bond strap is removed. Apply appropriate label provided next to switch handle.

For Underground Service Only.

Use 75°C Copper or Aluminum Conductors.



See adjacent labels for additional marking information.

49311207

D Siemens Industry, Inc. Norcross, Georgia U.S.A. 40900081 0101 Rev.01

SIEMENS

If cover interlock is defeated, it will be necessary for cover interlock plate to be positioned over opening and retightened.

This device has a maximum short circuit current rating of 100,000 amps RMS symmetrical at 240 Volts~, Use Class T (300V) fuses only. Continuous load current not to exceed 80% of the rating of the fuses in other than motor circuits.

Lugs for Phase and Neutral Connections (not supplied)						
NEMA Lug ^①	MFG	Wire Range	Туре	No. Wires per phase	Torque (lbin.)	
LK12600N2	Siemens	#2-600 kcmil	Mechanical	2	500	
LK12750N2	Siemens	300-750 kcmil	Mechanical	2	500	
LK13500N2	Siemens	1/0-500 kcmil	Mechanical	3	500 ②	
LK14500N2	Siemens	1/0-500 kcmil	Mechanical	4	500	
LK13750N2	Siemens	300-750 kcmil	Mechanical	3	500 ②	
2ACL-500	ILSCO	500 kcmil	Compression	3	NA ③	
2ACL-600	ILSCO	600 kcmil	Compression	2	NA ③	
2ACL-750	ILSCO	750 kcmil	Compression	2	NA ③	

① Order one mechanical lug kit for main breaker and neutral conversions. Contact lug manufacturer for compression lug quantities supplied for each kit.

Kit contains more than one lug type.

(3) See lug manufacturer's instruction sheet supplied with the connector for tool, die, and number of crimps.

Ground terminal G: Wire size #4-300 kcmil Torque terminal to 250 lb.-in.

Torque fuse mounting hardware to 225 lb-in.

Connect Modules Using: Cat. No. Torque 400-440 lb-in (35-36 ft.-lb.) **Quick Connect** QC1

IMPORTANT - for use with:

HWF OTTAKT - 101 use with.				
Module Description	Siemens Series#			
Main Breakers	WB(M), WEB(M), WXB(M), BFT(M)			
Switches	WMP, WS, WES, WXS			
Tap/Terminal Boxes	WTB, WET, WT_PU, WTBN, WBT(M)			
Pull Boxes	WMMB			
Meter Module	(W)MM, (W)MT, (W)ML, (W)MK, (W)MLZ(F), (W)MN			
Meter Combinations	WC, WCL, WCT,			
Extension Box	WSP, WSPD			
Bussed Elbow	BE, WELB			

Important: Do not allow petroleum based (hydrocarbon) sprays, chemicals, solvents or any paint to contact interior components. Petroleum based chemicals can cause degradation of electrical insulating materials.

49311208

D Siemens Industry, Inc. Norcross, Georgia U.S.A. 40900081 0201 Rev.01

© 2019 Copyright Siemens Industry, Inc.

[®] The National Electrical Code is a registered trademark of the National Fire Protection Association. © 2019 Copyright Siemens Industry, Inc.