

APR 28 2003

Certificate of Compliance

Certificate: 1079322

Master Contract: 154852 (LL 24563)

Project: 1311847

Date Issued: March 24, 2003

Issued to: Siemens Energy & Automation Inc.
Distribution Products Div.
811 North Main Street
Bellefontaine, OH 43311
U.S.A.
Attention: Mr. Mike Holland

The products listed below are eligible to bear the CSA Mark shown



Issued by: C. Law, P. Eng.

Authorized by: Nick Alfano
Operations Manager

PRODUCTS

CLASS 4651 01 - SWITCHES - Enclosed

Enclosed Switches, with or without fuses, with or without neutral, Cat No GFC, GNFC, HFC, HNFC, with suffix N or R or NR or J or S or without suffix, 400A and 600A, 240, 600V ac, 125, 250, 600V dc, 1 and 3 phase.

Horsepower Ratings: Refer to Table 1

APPLICABLE REQUIREMENTS

- | | | |
|--------------------------|---|--|
| CAN/CSA-C22.2 No 4-M89 | - | Enclosed Switches |
| CAN/CSA-C22.2 No 94-M91 | - | Special Purpose Enclosures |
| CAN/CSA-C22.2 No 0.12M85 | - | Wiring space and wire bending space for enclosures |
| CAN/CSA-C22.2 No 0.4M82 | - | Bonding and Grounding of Electrical Equipment |



Supplement to Certificate of Compliance

Certificate: 1079322

Master Contract: 154852 (LL 24563)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1311847	March 24, 2003	Update report to cover alternate construction.
1079322	August 8, 2000	Enclosed switches, Cat Nos GFC, GNFC, HFC, HNFC, 400, 600A.



Certificate of Compliance

Certificate: 1079316 (LL24563)

Master Contract: 154852

Project: 1613030

Date Issued: 2005/01/21

Issued to: Siemens Energy & Automation, Inc.

811 N. Main St.
Bellefontaine, OH 43311
USA
Attention: Mr. Mike Holland

The products listed below are eligible to bear the CSA Mark shown



Issued by: Charles Law, P. Eng.

Authorized by: Nick Alfano, Operations
Manager

A handwritten signature in black ink, appearing to read 'N. Alfano'.

PRODUCTS

CLASS 4651 01 - SWITCHES - Enclosed

Enclosed Switches, with or without fuses, with or without neutral, Cat Nos GFC, GNFC, HFC, HNFC, with suffix N or R or NR or J, or without suffix 30, 60, 100 and 200A, 240, 600V ac, 125, 250, 600V dc, 1 and 3 phase.

Enclosed switches with receptacles, with or without fuses, Cat No's HF, HNF, with suffix, S, J, CH, or W, 30, 60, and 100A, 240, 600 Vac 1 and 3 phase, 250 Vdc

Horsepower Ratings: Refer to Table 1 of Certification report



Certificate: 1079316 (LL24563)

Master Contract: 154852

Project: 1613030

Date Issued: 2005/01/21

Short Circuit Ratings: Refer to Certification Report

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 4 - Enclosed Switches

CAN/CSA-C22.2 No 94 - Special Purpose Enclosures

CAN/CSA C22.2 No 0.12 - Wiring space and wire bending space for enclosures

CAN/CSA-C22.2 No 0.4 - Bonding and Grounding of Electrical Equipment



Supplement to Certificate of Compliance

Certificate: 1079316

Master Contract: 154852

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1613030	2005/01/21	Update Report 1079316 to cover new Cat. Nos. and alternate construction

History

1311846 March 24, 2003 Update descriptive material and add new cat. nos.

1079316 August 8, 2000 Original Certification