

UL International Germany GmbH

Frankfurter Strasse 229 · D-63263 Neu-Isenburg
Telefon +49 (0) 61 02 369-0 · Fax +49 (0) 61 02 369-280



A Subsidiary of
**Underwriters
Laboratories Inc.**

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 0124001-E47705

ISSUE DATE: January 24, 2001

Page 1 of 2

Issued to: Siemens AG, A & D CP TS2
Werner- Von- Siemens-Straße 48
92220 Amberg, Germany

Report Reference: E47705 ML Issued December 14, 1999

This is to Certify that representative samples of: Manuel Motors Controllers: AC cam-type controllers, open type, for flush mounting, single-or multi-pole, for change-over, reversing, speed control and similar applications with the maximum ratings shown below at 600 Vac. 3-phase unless otherwise noted.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard for Industrial Control Equipment UL 508

Additional Information: Models and Rating Information see Page 2

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:

Dirk Müller
Underwriters Laboratories Inc.

Review Engineer:

Kevin Connelly
Underwriters Laboratories Inc.

Geschäftsführer: G. T. Castino, S.J. Bhatia, L.W. Newman
HRB 11290 Amtsgericht Offenbach/Main

Satellite Office:
UL International Germany GmbH
Candidplatz 13, D-81543 München
Tel. +49 (0) 89 622 703-0, Fax +49 (0) 89 622 703-31

UL International Germany GmbH

Frankfurter Strasse 229 · D-63263 Neu-Isenburg
Telefon +49 (0) 61 02 369-0 · Fax +49 (0) 61 02 369-280

CERTIFICATE OF COMPLIANCE - ADDENDUM



A Subsidiary of
**Underwriters
Laboratories Inc.®**

CERTIFICATE NUMBER: 0124001-E47705

Page 2 of 2

ISSUE DATE: January 24, 2001

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Manual Motor Controller:

Model	Rating	Hp 1-phase	Hp 3-phase
3LD20	16A, 600Vac	0.5hp 120V, 1.5hp 240V	3hp 240V, 7.5hp 480V, 10hp 600V
3LD21	25A, 600Vac	2hp 120V, 3hp 240V	7.5hp 240V, 10hp 480V, 15hp 600V
3LD22	32A, 600Vac	2hp 120V, 3hp 240V	10hp 240V, 20hp 480V, 20hp 600V
3LD25	63A, 600Vac	10hp 240V	15hp 240V, 40hp 480V, 50hp 600V
3LD27	100A, 600Vac	-	30hp 240V, 60hp 480V, 75hp 600V
3LD28	125A, 600Vac	-	40hp 240V, 75hp 480V, 100hp 600V

Accessories:

3LD92*	Auxiliary Switches	reted A600, P600
3LD92*	4 th-Pole	rating same as main controllers
3LD92*	N-clamp	rating same as main controllers
3LD92*		environmental rated for Types 1, 4X and 12
3LD2*-64*		environmental rated for Types 1, 4X and 12
3LD2*-65*		environmental rated for Types 1, 4X and 12
3LD2*-66*		environmental rated for Types 1, 4X and 12

Engineer:

Dirk Müller

Review Engineer:

Kenneth Connelly

Geschäftsführer: G. T. Castino, S.J. Bhatia, L. W. Newman
HRB 11290 Amtsgericht Offenbach/Main

Satellite Office:
UL International Germany GmbH
Candidplatz 13, D-81543 München
Tel. +49 (0) 89 622 703-0, Fax +49 (0) 89 622 703-3