

SIEMENS

GARY GLUCK

SIEMENS INDUSTRY

LOW AND MEDIUM VOLTAGE DIVISION

INFRASTRUCTURE AND CITIES SECTOR

6520 PLATT AVE

PMB 177

WEST HILLS, CA 91307

TELEPHONE : (818) 887-9472

EMAIL gary.gluck@siemens.com

FACSIMILE : (678) 297-8957

1 May, 2012

To : Southern California Edison

Attn: Gary Gonzales

Re : Siemens Visible Contact Switches for PV applications

Gentlemen,

This letter follows up our meeting earlier today where the Siemens HCP Switch was reviewed for compliance with the requirements set forth in the SCE NEM Interconnection Handbook.

In attendance at the meeting were:

Gary Gonzales, Rich Viveros, Robert Peralta, and Ilia Gueorguieva –all with SCE

Michael Mennes, Elmer Savage and Gary Gluck-all with Siemens

It was determined that the switch met the criteria and is acceptable for the applications described in that handbook.

The switch mechanism that was reviewed is common to the following Siemens part numbers:

3-Pole, Horizontal Mount ①

Catalog Number	Maximum Ampere Rating	Maximum AC Voltage Rating ^②	Fuse Class	Dimensions (inches*)			Horsepower Rating							
							240V		480V		600V		250V DC	
				H	W	D	Std	Max	Std	Max	Std	Max		
HCP367HJ400	400	600	J	16.25	17.22	7.38	50	125	100	250	125	350	40	
HCP367HJ600	600	600	J	16.25	17.22	7.38	75	200	150	400	200	400	40	
HCP327HT	800	240	T	16.25	17.22	7.38	100	250	—	—	—	—	50	
HCP367H	800	600	L	16.25	17.22	7.38	100	250	200	500	250	500	50	
HCP328HT	1200	240	T	16.25	17.22	7.38	100	250	—	—	—	—	50	
HCP368H	1200	600	L	16.25	17.22	7.38	100	250	200	500	250	500	50	

3-Pole, Vertical Mount

HCP367VJ400	400	600	J	17.00	16.25	7.38	50	125	100	250	125	350	40
HCP367VJ600▲	600	600	J	17.00	16.25	7.38	75	200	150	400	200	400	40
HCP327VT	800	240	T	17.00	16.25	7.38	100	250	—	—	—	—	50
HCP367V	800	600	L	17.00	16.25	7.38	100	250	200	500	250	500	50
HCP328VT	1200	240	T	17.00	16.25	7.38	100	250	—	—	—	—	50
HCP368V	1200	600	L	17.00	16.25	7.38	100	250	200	500	250	500	50

This table is an excerpt from Siemens Speedfax page 5-22(2011-2012 edition)

Thank you for taking the time out of your schedule to review the product. Please don't hesitate to contact me if you have any questions regarding this matter.

Sincerely,
Gary Gluck