

# TALON

## Rainproof Combination Metering

Catalog Number

**MM0202L1100EY (OVERHEAD SERVICE ONLY)**

Enclosure

**Type 3R**

**WARNING: CIRCUIT MAY BE LIVE WITH METER REMOVED.**

DEVICE RATING: 100 AMPS MAXIMUM

120/240 V~, 1 PHASE, 3 WIRE

208Y/120 V~, 1 PHASE, 3 WIRE, WHEN 5th JAW IS INSTALLED.

(DERIVED FROM 3 PHASE - 4 WIRE SYSTEM)

LIMITED TO 2-POLE BREAKERS.

METER SOCKET RATING: 100 AMPS CONTINUOUS.

FOR INSTALLATION BY A QUALIFIED PERSON IN ACCORDANCE WITH ALL LOCAL ELECTRICAL CODES AND/OR THE NATIONAL ELECTRICAL CODE.®

**SUITABLE FOR USE AS SERVICE EQUIPMENT.** WHEN USED AS SERVICE EQUIPMENT, BOND NEUTRAL AND APPLY "SERVICE DISCONNECT" LABEL NEAR THE DISCONNECT HANDLE.

THIS DEVICE HAS A MAXIMUM SHORT CIRCUIT CURRENT RATING OF 65,000 AMPS RMS SYMMETRICAL AT 240 V~ MAXIMUM. (WATT-HOUR METER NOT INCLUDED IN SHORT CIRCUIT CURRENT RATING). THE ACTUAL RATING IS DEPENDENT ON THE MAIN BREAKER INSTALLED IN THIS PANELBOARD. ANY CIRCUIT BREAKER INSTALLED OR REPLACED IN THIS PANELBOARD MUST BE MANUFACTURED BY SIEMENS AND MUST BE OF THE CORRECT TYPE AS INDICATED IN THE TABULATION BELOW.

MAX SHORT CIRCUIT CURRENT RATING IN RMS SYMMETRICAL AMPERES	WHEN THE INSTALLED BREAKER TYPE IS:
65,000	Murray MP-MT Siemens HQP
22,000	Murray MP-HT, MP-MT Siemens QPH, HQP
10,000	Murray MP-T, MP-GT Siemens QP, QPF

### RX TYPE HUBS

TRADE SIZE	CAT. NO.
1-1/4 INCH	EC38597
1-1/2 INCH	EC38598
2 INCH	EC38599
2-1/2 INCH	EC38600

FOR BREAKERS WITH TRIPPED POSITION IN CENTER, RESET BREAKER BY MOVING HANDLE TO "OFF" AND THEN TO "ON".

### ACCESSORIES

EQUIP GND BARS: ECLX SERIES

5TH JAW: EC5J

**WARNING:** THIS EQUIPMENT HAS BEEN DESIGNED FOR USE ONLY WITH CIRCUIT BREAKERS LISTED ABOVE. USE OF OTHER CIRCUIT BREAKERS IN THIS EQUIPMENT COULD RESULT IN PERSONAL INJURY OR PROPERTY DAMAGE AND WILL VOID THE WARRANTY.

**IMPORTANT:** DO NOT ALLOW PETROLEUM BASED (HYDROCARBON) SPRAYS, CHEMICALS, SOLVENTS OR ANY PAINT TO CONTACT INTERIOR COMPONENTS. PETROLEUM BASED CHEMICALS CAN CAUSE DEGRADATION OF ELECTRICAL INSULATING MATERIALS.

Siemens Industry, Inc. Norcross, Georgia U.S.A.

**D**

40900587 0101 Rev.A

® The National Electrical Code is a registered trademark of the National Fire Protection Association.

© 2012 Copyright Siemens Industry, Inc.