

Type Test Certificate

Siemens Protection Devices Limited.

Test Certification: 7PG11 AR

Tested Equipment: 7PG11
Auxiliary

Tested According to: IEC/EN 60255-5

Performed Tests:

- 1 Properties at reference conditions
- 2 State after stress
- 3 Performance at influencing quantities
- 4 Safety

Test Results: The equipment has successfully passed the type test. The equipment did not show any changes and was in full working order subsequent to these tests.

January 2016

Paul Mudditt
Head of R&D
EM DG SPDL UK

Bruce Watson
Head of PLM
EM DG SPDL UK