



IEC 61850 Certificate Level A¹

International
Usersgroup

No. 30720460-Consulting 07-1387

Issued to:
Siemens A.G., PTD EA
Protection and Substation Control Systems
Wernerwerkdamm 5
D-13623 Berlin
Germany

For the product:
Siprotec V4
7UT635 Multifunctional differential
protection for transformers (2 - 5 windings
/ ends)
Firmware V04.60
EN100 V04.00



The product has not shown to be non-conforming to:
IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "SIPROTEC 4 Ethernet Module EN100 IEC 61850 Electrical / Optical Interface 100 MBit Manual, Edition May 2007, C53000-G1100-C167-7", "MICS, Mapping family 7UT613_63 Mappingversion 1 Revision 5" and product's extra information for testing: "SIPROTEC Differential Protection 7UT613/63x V4.6 IEC 61850 PIXIT, C53000-G1176-C184-3".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2):


1 Basic Exchange (19/24)	9ab Generic Object Oriented Substation Event (16/22)
2+ Data Set Definition (26/29)	12a Direct Control (5/12)
4 Setting Group Selection (2/3)	12c Enhanced Direct Control (4/13)
5 Unbuffered Reporting (16/18)	12d Enhanced SBO Control (12/20)
6 Buffered Reporting (17/20) ²	13 Time Synchronization (3/5)
	14 File Transfer (4/7)

This Certificate includes a summary of the test results as carried out at in with UniCASim 61850 version 3.16.00 with test suite 3.16.01 and UniCA 61850 analyzer 4.15. The test is based on the UCA International Users Group Device Test Procedures version 2.2. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30720460-Consulting 07-1386 will prevail.

The tests have been carried out on one single specimen of the product as referred above and submitted to KEMA by Siemens. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, October 11, 2007


S.J.L.M. Janssen
Managing Director KEMA Consulting


R. Schimmel
Certification Manager

¹ Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

² Buffered reporting may cause interoperability issues due to implementation of tissue #453

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, RpN5, Rp8, Rp9, Rp11
6: Buffered Reporting ³	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10, Br11, Br13
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7, Gop10	Gop1, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a Direct control	CtlN3, CtlN8 DOs1, DOs3	Ctl2
12c: Enhanced Direct Control	CtlN3, CtlN8 DOes2, DOes5	
12d: Enhanced SBO Control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9 SBOes1, SBOes2, SBOes3	Ctl2, Ctl7, CtlN11
13: Time Sync	Tm1, Tm2, TmN1	
14: File Transfer	Ft1, Ft2ab, Ft4, FtN1ab	

³ Buffered reporting tissue #453 has successfully been tested, compare test report for details